

Attestation

BREEAM[®]

On 16 December 2021 (VOC content) and 16 april 2019 (VOC emission), Eurofins Product Testing A/S received a sample of a paint with the product name:

Sigma Air Pure Supermatt

supplied by

PPG ARCHITECTURAL COATINGS UK LIMITED

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 and ISO 11890-2 testing standards (See test report no. 392-2019-00153501_A_EN_05_rev1 and no. 392-2021-00630002_XG_EN_02_rev1).

The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions and VOC content by complying with:

- **BREEAM[®] International: Compliance with Exemplary criteria on both VOC emission and VOC content** of BREEAM International: New Construction 2021, Technical Manual – SD250: Hea 02 Indoor Air Quality (version 6.0. of December 2021).
- **BREEAM[®] UK: Compliance with Exemplary criteria on both VOC emission and VOC content** of BREEAM UK: New Construction 2018, Technical Manual: Hea 02 Indoor Air Quality (version SD5078 issue 3.0 of July 2019).

30 May 2022



Laura Hartung Sørensen
Analytical Service Manager



Rasmus Verdier
Analytical Service Manager