

Attestation

WELL Building Standard™

On the 2nd of October 2023, Eurofins Product Testing A/S received a sample of paint with the product name:

Sigmacryl Universal Matt

supplied by

PPG Coatings Nederland BV

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the AgBB (2021) with EU LCI VOC threshold values and ISO 11890-2 (2020) test standards (See test report no. 392-2023-00460721_A_EN and 392-2023-00460722_XG_EN).

The tested product complies with the requirements of WELL v2 Feature X06 VOC Restrictions: Part 1 by complying with:

VOC emissions specifications:

- The requirements of AgBB (2021)

VOC content specifications:

- The requirement of the EU Decopaint Directive 2004/42/CE for 'Interior matt walls and ceilings' having a VOC content below 30 g/L.

5 December 2023



Henriette Buch Lauersen
Analytical Service Manager



Laura Hartung Sørensen
Analytical Service Manager

The International WELL Building Institute (IWBI) is a public benefit corporation whose mission is to improve human health and well-being in buildings and communities across the world through its WELL Building Standard (WELL). WELL™ and the related logo are trademarks owned by the IWBI and are used with permission.